



## SECTION 08 33 00

### Overhead Coiling Doors

*To display hidden notes to specifier, select tools/ options/ view/ hidden text.*

#### GENERAL

##### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

##### 1.2 SECTION INCLUDES

- A. Overhead Coiling Counter Doors

##### 1.3 RELATED SECTIONS

- A. Section 05 10 00 - Structural Metal Framing.
- B. Section 06 10 00 - Rough Carpentry.
- C. Section 09 90 00 - Painting and Coating.
- D. Section 26 05 00 - Common Work Results for Electrical.

##### 1.4 REFERENCES

- A. ASTM A480/A480M-04; 2004 - Standard Specification for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet, and Strip.
- B. ASTM A653/A653M-03; 2003 - Standard Specification for Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- C. ASTM A666-00; 2000 - Standard Specification for Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- D. ASTM B209-04; 2004 - Standard Specification for Aluminum - Alloy Sheet and Plate.
- E. ASTM B221-02; 2002 - Standard Specification for Aluminum - Alloy Extruded Bars, Rods, Wires, Shapes and Tubes.
- F. National Fire Protection Association NFPA 80, 2013 Edition - Standard for Fire Doors and Fire Windows.
- G. Underwriters Laboratories (UL) 10B, 1997 Edition - Standard for Fire Tests of Door Assemblies.

##### 1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 - Administrative Requirements.
- B. Product Data: For each type and size of overhead coiling door and accessory.
  - 1. Include construction details, material descriptions, dimensions of individual components, profiles for slats, and finishes.
  - 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished accessories.
  - 3. Include description of automatic closing device and testing and resetting instructions.
- C. Shop Drawings: For each installation and for special components not dimensioned or

detailed in manufacturer's product data.

1. Include plans, elevations, sections, and mounting details
  2. Include details of equipment assemblies and indicate dimensions, required clearances, and components.
  3. Provide BIM models upon request.
  4. Show controls, locking devices, [detectors] [fusible links], and other accessories.
- D. Samples for Initial Selection: Upon request, provide manufacturer's finish charts showing full range of colors and textures available for units with factory applied finishes.
1. Include similar samples of accessories involving color selection
- E. Samples for Verification: Upon request, provide for each type of exposed finish on the following components in manufacturer's standard sizes.
1. Curtain slats.
  2. Bottom bar.
- I. Sustainable Design Submittals:
1. Recycled products: Indicate percentage of recycled material used in the manufacturing of products and percentage classified as post-consumer.
  2. Regional products: Indicate location of product manufacturer and distance from manufacturing facility to project site.
- J. Closeout Submittals:
1. Operation and maintenance data.

## 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications:
1. Company specializing in the manufacturing of products specified in this section and with a minimum of five years experience.
- B. Installer Qualifications: Installer shall be authorized and qualified to install overhead door systems on the type and scope of project specified.
1. Maintenance Proximity: Not more than [insert number] hours normal travel time from installers place of business to project site.

## 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of all materials in accordance with federal, state and local laws.

## 1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

## 1.9 COORDINATION

- A. Coordinate with other operations and installation of adjacent materials to avoid damage to installed materials.

## 1.10 WARRANTY

- A. Warranty: Manufacturer's warranty that all parts and components are to be free from defects in materials and workmanship for 1 year.
- B. Warranty: Manufacturer's warranty that all parts and components, except counterbalance spring and finish, are to be free from defects in materials and workmanship for 5 years. Counterbalance springs to be warrantied for 1 year.

## PART 2 PRODUCTS

## 2.1 MANUFACTURERS

- A. Acceptable Manufacturer: C.H.I. Overhead Doors, which is located at: 1485 Sunrise Dr. ; Arthur, IL 61911; Toll Free Tel: 800-590-0559; Fax: 217-543-4454; Email: [AIA@chiohd.com](mailto:AIA@chiohd.com); Web: [www.chiohd.com](http://www.chiohd.com).
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01 60 00 - Product Requirements.

## 2.2 PERFORMANCE REQUIREMENTS

- A. Overhead Coiling Counter Doors
  - 1. Seismic Performance: Overhead coiling doors shall be evaluated for seismic performance to withstand the effect of earthquake motions determined according to ASCE/SEI 7.
  - 2. Operation: Design complete door assembly including operator for usage of up to 20 cycles per day.
- B. Source Limitations: Provide overhead coiling doors from one manufacturer for each type of door. Provide operators and other accessories from source acceptable to overhead coiling door manufacturer.

## 2.3 MATERIALS

- A. Galvanized Steel Sheet:
  - 1. Galvanized commercial steel, (CS type) per ASTM A653/A653M, G90 and G60 coating class.
- B. Stainless Steel Sheet: ASTM A480/A480M or ASTM A666; Type 304, roll form temper.
- C. Aluminum:
  - 1. Extrusions: ASTM B221, alloy and temper best suited to application.
  - 2. Sheet: ASTM B209, alloy and temper best suited to application.
- D. LEED Requirements:
  - 1. Recycled content: Minimum [ ] percent with minimum [ ] percent classified as post-consumer.

## 2.4 DOOR ASSEMBLY

- A. Overhead Coiling Counter Doors
  - 1. Basis of Design: C.H.I. Overhead Doors model 6544.
  - 2. Construction:
    - a. Curtain: Constructed from interlocking slats formed from the following.
      - 1) Material:
        - a) 16 gauge (.050) aluminum.
        - i) Finish:
          - a. Clear Anodized Finish
          - b. Powder Coat: [RAL# ] [Custom Color Match]
      - 2) Profile:
        - a) Flat, non-insulated, 1-1/2 inches high by 1/2 inch deep.
      - 3) End locks: Nylon, attached to every other slat to act as wearing surface and prevent lateral movement.
      - 4) Bottom bar:
        - a) Extruded aluminum tube type bottom bar.
          - i) Bottom Bar Finish
            - a. Clear Anodized Aluminum



- 3) Interlock Switches: Equip power-operated doors with safety interlock switch to disengage power supply when door is locked.
3. Mounting:
  - a. Face of wall and above lintel.
  - b. Face of wall and under lintel.
  - c. Between jamb and above lintel.
  - d. Between jamb and under lintel.
4. Manual Operation
  - a. Manual push up.
  - b. Awning crank.
5. Electric Motor Operator: Provide operator unit, UL listed and UL labeled, size as recommended by manufacturer, capable of driving door at a speed of no less than 8 inches per second nor more than 12 inches per second.
  - a. Operator Location:
    - 1) Internally mounted in barrel.
    - 2) Externally mounted on drive side of shutter.
  - b. Power Supply:
    - 1) 115 VAC, single phase
  - c. Control Station:
    - 1) 24 V three button control station with open, close, and stop buttons
    - 2) 24 V three button control station with open, close, and stop buttons and keyed lockout.
    - 3) 24 V key control station with open and close contacts.
    - 4) 24 V key control station with open/close contacts and stop button.
      - a) NEMA 1 Surface mounted for interior.
      - b) NEMA 1 Flush mounted for interior.
      - c) NEMA 4 Surface mounted for exterior.
      - d) NEMA 4 Flush mounted for exterior.

## PART 2 EXECUTION

### 2.1 EXAMINATION

- A. Examine substrates, areas, and conditions for compliance with requirements for substrate construction and other conditions affecting performance of the work.
- B. Examine locations of electrical connections.
- C. Proceed with installation only after all unsatisfactory conditions have been corrected.

### 2.2 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Anchor to adjacent construction without distortion or stress.
- C. Fit and align door and shutter assembly including hardware, plumb, level and square to ensure smooth operation.
- D. Complete wiring from operator to controls and components.
- E. Coordinate installation of electrical service from power supply to operator.
- F. Complete wiring from operator to controls and components.
- G. Coordinate installation of electrical service from power supply to operator.

### 2.3 ADJUSTING

- A. Adjust hardware and moving parts so that doors operate smoothly throughout full operating range.

- B. Adjust seals to provide a tight fit around the entire perimeter.

#### 2.4 MAINTENANCE SERVICE

- A. Initial Maintenance Service: Beginning at Substantial Completion, maintenance service shall include [three] [six] [nine] [twelve] months full maintenance by skilled employees of installing company. Include [monthly] [quarterly] preventive maintenance, repair or replace of worn or defective components, lubrication, cleaning, and adjusting as required for door operation. Parts and supplies shall be manufacturer's authorized replacement parts and supplies.
  - 1. Perform maintenance, including emergency callback service, during normal working hours.
  - 2. Include 24 hour per day, seven days per week, emergency callback service.

#### 3.5 DEMONSTRATION

- A. Demonstrate proper operation to Owner.
- B. Perform fire door and shutter drop tests in presence of Owner or owner's representative. Require signature for manufacturer supplied drop test form.

END OF SECTION