



Seal

TOWN & COUNTRY PLASTICS, INC.  
POST OFFICE BOX 269  
MORGANVILLE, NJ 07751  
PHONE: (732) 780-5300 - FAX: (732) 294-0001

METHOD 2C  
NEUTRALIZATION SYSTEM DETAIL

DETAIL:  
METHOD 2C  
NEUTRALIZATION SYSTEM  
DETAIL

Revisions:  
ORIGINAL - 12.14.2016  
REV 1 - 6.13.2017  
REV 2 - 9.22.2017  
REV 3 - 10.02.2017

Drawn: JIG  
Checked: JIG  
Scale: NTS  
Date: 12.14.2016

- ① LIMESTONE NEUTRALIZING / DILUTION TANK #1
- ② MIXING AND FINISHING TANK #2
- ③ SAMPLING TANK #3
- ④ ACID FEED TANK #4 (ACID REAGENT TANK)
- ⑤ CAUSTIC / ALKALI FEED TANK #5 (CAUSTIC REAGENT TANK)
- ⑥ SPILL CONTAINMENT PALLET
- ⑦ CHEMICAL AGITATOR / MIXER
- ⑧ AGITATOR SHAFT AND MIXING BLADE
- ⑨ PH PROBE ASSEMBLY
- ⑩ PH PROBE SENSOR
- ⑪ CAUSTIC CHEMICAL FEED PUMP
- ⑫ ACID CHEMICAL FEED PUMP
- ⑬ PH PROBE ASSEMBLY WITH SUPPORT
- ⑭ ACID VENT CONNECTIONS
- ⑮ CONTROL PANEL
- ⑯ THREADED PP SCHEDULE 80 PIPE\* WITH THREADED JOINTS WITH TEFLON TAPE
- ⑰ CONCRETE PAD OR EPOXY COATED STEEL STAND, BY INSTALLER
- ⑱ LOW LIQUID LEVEL ALARM ASSEMBLIES
- ⑲ POLYPROPYLENE LEAK DETECTOR WITH SWITCH BOX AND ALARMS
- ⑳ POLYPROPYLENE SHUT OFF VALVE
- ㉑ MODEL #WMS-1 SIGN
- ㉒ MODEL #WMS-2 SIGN
- ㉓ PP-44T LEAK DETECTION FLOAT ASSEMBLY TO BE INSTALLED IN SPILL CONTAINMENT PALLET AND/OR PIT FLOOR

\*T&C CAN PROVIDE AT EXTRA COST, IF LIST OF P-V-F GIVEN TO T&C BY PLUMBING CONTRACTOR, PRIOR TO INSTALLING\*

