			COMPRESSOR DA			
Γ			otary Compressor: L DATA - FOR CO	-		
-	1 Manufacturer: Mattei Compressors Inc.					
-		Model Number: AC 11 LX		Date:	Oct-14	
	2	X Air-cooled	Water-cooled	Type:	Vane	
_		X Oil-injected	Oil-free	# of Stages:	1	
	3*	Rated Capacity at Full L a, e	oad Operating Pressure	70.0	acfm ^{a,e}	
	4	Full Load Operating Pressure b		100	psig ^b psig ^c	
	5		timum Full Flow Operating Pressure ^c			
		Drive Motor Nominal R	ive Motor Nominal Rating		hp percent	
		Drive Motor Nominal Efficiency		92.4		
	8	Fan Motor Nominal Rating (if applicable)		n/a	hp	
-	9	Fan Motor Nominal Efficiency		n/a	percent	
-	10*	Total Package Input Pov	ver at Zero Flow ^e	3.9	kW ^e	
_	11 Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d			15.1	kW^d	
	12* Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^e			21.57	kW/100 cfm ^e	
	Consult C	ls that are tested in the CAGI F AGI websitefor a list of partici	Performance Verification Propants in the third party verification	ogram, these items are veri ication program:	www.cagi.org	strator.
C/	NOTES: Member	ISO 1217, Annex C; A b. The operating pressure for this data sheet. c. Maximum pressure atta maximum pressure atta d. Total package input po e. Tolerance is specified i	rge terminal point of the comp CFM is actual cubic feet per n at which the Capacity (Item 3 inable at full flow, usually the inable before capacity control wer at other than reported ope n ISO 1217, Annex C, as show	inute at inlet conditions.) and Electrical Consumption : unload pressure setting for begins. May require additio rating points will vary with c	n (Item 11) were measured load/no load control or the nal power.	
			Volume Flow Rate at specified conditions		Specific Energy Consumption	No Load / Zero Flo Power
		<u>m³ / min</u> Below 0.5	<u>ft3 / min</u>	% +/- 7	% +/- 8	
		0.5 to 1.5	Below 15 15 to 50	+/- / +/- 6	+/- 8 +/- 7	+/- 10%
		1.5 to 15	50 to 500	+/- 5	+/- 6	./ 10/0
OT 030		Above 15	Above 500	+/- 4	+/- 5	

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.

10/11 R8