

# Modeling of the Spent Fuel Pool During Severe Accidents Using the MAAP Code

By: Matthew Kennedy, Nuclear Engineer

The spent fuel pool is a plant system which provides cooling of full or partially irradiated fuel rods. 10 CFR Part 72 requires that spent fuel cladding be protected during storage against degradation that leads to gross ruptures. Nuclear fuel cladding has been shown to degrade and rupture at high storage temperatures; therefore assemblies are stored in a large pool of water until the assembly decay heat is low enough for packaging and transportation to an ultimate repository or temporary dry storage. Figure 1 provides a representative spent fuel pool with a checkerboard loading pattern. The checkerboard loading pattern is used to provide spacing of the relative hot and reactive assemblies (red) by placing the cooler (blue and yellow) assemblies or empty (white) rack locations in-between.




Figure 1: Top-Down View of Checkerboard Pattern of a Representative Spent Fuel Pool

Recent industry events have shown that during beyond design basis accidents there is a potential for the fuel in the spent fuel pool to heat up, fail, and release radioactive material to the environment. With the current state of an ultimate fuel repository in question, in the US, many utilities have looked to temporary storage solutions of spent fuel. These temporary options include dry storage, expansion of current pool inventories, and or shipping of fuel to other reactor sites for temporary storage.

Dry fuel storage is expensive (construction, analysis, and licensing costs) and can only be used when the decay heat has been significantly reduced through radioactive decay. Therefore, this option is usually used as a last resort option for the temporary storage of spent nuclear fuel. A more efficient and less costly method of spent nuclear fuel storage is to expand the capacity of the current spent fuel pools. In order to expand the current pool inventories, many utilities have used the advancements in neutronic and thermal hydraulic models and calculations to refine earlier analysis. This has led to the development of high density spent fuel pool racks. High density fuel racks allow for fuel to be stored closer, thereby increasing the number of assemblies which can be stored in the pool, without violating the criticality or temperature limits of the system.

Due to the recent industry events, several utilities have undertaken initiatives to understand how the fuel stored in the spent fuel pool would behave under a beyond design basis accident. Accidents in the spent fuel pool are different from accidents in the reactor due to the large thermal inertia in the spent fuel pool water and the lower initial decay heat in fuel assemblies. Additionally, transient analysis of the spent fuel pool is complicated by the fact that multiple fuel designs, power levels, and irradiation times are present in the stored nuclear fuel. The Modular Accident Analysis Program (MAAP), which is owned by the Electric Power Research Institute (EPRI) and developed and maintained by Fauske & Associates LLC, is a program which has the ability to model the transient response during severe accident scenarios in the spent fuel pool. This model includes the initial fuel heat up upon loss of cooling, zirc-air/steam oxidation phenomena, fuel melting, Molten Core-Concrete Interaction (MCCI), and fission product release. The spent fuel pool model was first included in MAAP5 Version 5.01 and has been continuously improved in later versions.

Figure 2 and Equation 1 provide a simplistic model of the calculations which are considered in the MAAP simulation. Figure 2 and Equation 1 show that the pool heat  $Q_{pool}$  is determined by the radiation heat transfer ( $Q_{rad}$ ) from the uncovered portion on a fuel rod, the convection heat transfer ( $Q_{conv,steam}$  &  $Q_{conv,H2O}$ ) for both the steam and water portions, and the heat loss terms due to pool boiling ( $Q_{boil}$ ), and the spent fuel pool cooling system ( $Q_{cooling}$ ). This figure and equation provide a simplified analysis of the overall phenomena which occur during a severe accident in the spent fuel pool.




Figure 2: Detailed view of Heat Transfer from a Single Spent Fuel Pool Rod

$$Q_{pool} = Q_{rad} + Q_{conv,steam} + Q_{conv,H2O} - Q_{boil} - Q_{cooling} \quad \text{Eq. 1}$$

The MAAP spent fuel pool model has the ability to model transient and accident conditions which may occur in the spent fuel pool at nuclear reactor sites. The model also contains the ability to specify emergency cooling operations. These emergency operations can be either designed safeguards features or can be aligned under the sites emergency or FLEX strategies. Many utilities are interested in the timing of an accident mitigation system in order to prevent fission product release.

The following discussion provides a sample analysis of a loss of the spent fuel pool cooling system for an extended period for a hypothetical reactor site. The sample is a representative analysis for a spent fuel pool with 15 previous PWR batches (70-80 assemblies per batch) in addition to a full core offload (approximately 200 assemblies). This discussion provides some key metrics which may be evaluated during a severe accident.

Figure 3 shows the decrease in the spent fuel pool water over the transient. This figure shows the decrease in the water level due to steaming until the water level is approximately zero (at approximately 150 hours), signifying that the entire inventory has been boiled off. Figure 4 shows the maximum fuel temperature over the transient for the same sequence. This figure shows that the fuel temperature is constant until the water level reduces significantly. The fuel then rapidly increases in temperature due to the lack of cooling. This signifies that the spent fuel assemblies have become uncovered and the ability to cool the assemblies has been removed. The figure then shows a rapid decrease in the maximum spent fuel temperature, which corresponds to melting and relocation of the hottest fuel. A corium pool forms on the floor of the spent fuel pool and a phenomena known as Molten-Core Concrete Interaction (MCCI) begins. The maximum fuel temperature then increases because the older, lower decay power fuel, which did not heat up as quickly as the more recent, higher decay power, has a lack of cooling. This portion of the spent fuel then melts and adds to the corium pool on the floor which is seen by the second large decrease in the fuel temperature. The maximum temperature then reaches a constant value, slightly above zero, for the remainder of the sequence signifying that the entire pool inventory has melted and relocated to the floor of the spent fuel pool. The non-zero value corresponds to the default fuel temperature in the code once all of the fuel has been relocated from the core region. These two figures are just a sampling of the potential analysis potential which can be evaluated using the MAAP5 spent fuel pool model.




Figure 3: Spent Fuel Pool Water Level for a Hypothetical Loss of Spent Fuel Pool Cooling for an Extended Period




Figure 4: Maximum Fuel Temperature for a Hypothetical Loss of Spent Fuel Pool Cooling for an Extended Period

For further information, questions, or to inquire as to how Fauske & Associates, LLC can assist you in analysis of spent fuel or the spent fuel pool system please contact us at [info@fauske.com](mailto:info@fauske.com).

**For more information, contact:**

**Matthew Kennedy**  
**Nuclear Engineer**  
**(630) 323-8750**  
**[kennedy@fauske.com](mailto:kennedy@fauske.com)**

Fauske & Associates, LLC  
 16W070 83rd Street  
 Burr Ridge, IL 60527



[www.Fauske.com](http://www.Fauske.com)