



Lintel Table Guide for 150mm KORE ICF Wall

*Guide where Building Geometry Limits are as per those specified in IAB Certificate

Maximum Lintel Span	Bar Length (mm)	Ground Floor Openings		First Floor Openings	
		Bottom Steel	Top Steel	Bottom Steel	Top Steel
2200	3000	2T12	none		none
1900	2700	2T12	none	2T12	none
1600	2400	2T12	none	2T12	none
1300	2100	2T12	none	2T12	none
1000	1800	2T12	none	2T12	none
700	1500	2T12	none	2T12	none
400	1200	2T12	none	2T12	none

Notes

1. Links not required because of the KORE Bridges placed at 200mm centers in every KORE Panel. They may be added for additional strength.
2. The bar must extend 300mm past the insulation on each side of the opening.