


CO₂ Component Description

Cable Housing for Cable Operated Control Heads

Effective: April 2002
K-81-6030



PART NUMBER	CYLINDERS USED WITH		CYLINDER CENTERS		"A" DIMENSION	
	LBS	KG	IN	mm	IN	mm
INDUSTRIAL CO ₂						
202355	50-70	22.6-34.0	10.0	254	5.62	143
200822	100	45.3	11.625	295	7.12	181
MARINE CO ₂						
33157	50	22.6	9.5	241	5.12	130
202355	75	34.0	10.0	254	5.62	143
200822	100	45.3	11.0	292	7.12	181
FM-200						
260702	125-200	56.7-90.7	15.0	381	10.6	270
260951	350	158.7	18.0	457	13.6	346
263602	600	272.1	24.0	610	19.6	498

MATERIAL: BRASS, 625" (16MM) O.D. X .049" (1.28 MM) WALL

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly.
If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL INC., Ashland, MA 01721. Telephone: (508) 881-2000

Kidde Fire Systems
400 Main Street
Ashland, MA 01721 USA
Tel: (508) 881-2000
Fax: (508) 881-8920
<http://www.kiddefiresystems.com>