

DOUBLE COMBINATION CONTROL ACCESSORIES

DESCRIPTION

The Manual Release Switch is a dual actuation device which provides a means of manually discharging the automatic fire extinguishing system when used in conjunction with the Fike control panel.

The System Abort Switch is designed to be used in conjunction with other system equipment. It provides a temporary manual means by which the agent actuation circuit may be interrupted before automatic actuation occurs.

The “Main” to “Reserve” switch is used with systems that incorporate main and reserve (back-up) agent storage. The switch may utilize 1 or 2 Form “C” contact blocks which will provide an electrical path to either the “Main” or “Reserve” release device(s).

The Keyed Remote Reset Switch provides a method for resetting the Control Panel from a remote location.

These combination controls mount on a standard 4 gang masonry electrical box measuring 7-3/8” (187.3mm) wide x 3-3/4” (95.3mm) high x 2-3/8” (60.3mm) deep. (Fike P/N 02-2123)



10-1643
Manual Release/System Abort



10-1644
Manual Release/Main Reserve



10-1645
Manual Release/Remote Reset



10-1646
System Abort/Main Reserve



10-1647
System Abort/Remote Reset



10-1648
Main Reserve/Remote Reset

APPROVALS

- UL Listed
- ULC Listed
- FM Approved
- CSFM Approved
- BSA - 610-79-SA

Form No. P.1.73.01-1

(This page is left blank intentionally)

