

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx ExTC 19.0008X Page 1 of 3 Certificate history:

Status: Current Issue No: 0

Date of Issue: 2019-10-23

Applicant: Trolex Nome Limited

Unit 10a Newby Road

Hazel Grove Stockport SK7 5DY

United Kingdom

Equipment: RockMonitor XR System

Optional accessory:

Type of Protection: Intrinsic Safety

Marking: Ex ia I Ma

-20°C ≤ Tamb ≤ +50°C

Approved for issue on behalf of the IECEx

Certification Body:

Position:

Signature:

(for printed version)

Date:

Justin Gavranich

Certification Authority

2019-10-23

. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Ex Testing and Certification Pty Ltd 1/30 Kennington Drive Tomago NSW 2322 Australia





Certificate No.: IECEx ExTC 19.0008X Page 2 of 3

Date of issue: 2019-10-23 Issue No: 0

Manufacturer: Trolex Limited

Unit 10a Newby Road

Hazel Grove Stockport SK7 5DY

United Kingdom

Additional manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS:

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-25:2010-02 Edition:2.0 Explosive atmospheres - Part 25: Intrinsically safe electrical systems

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

AU/ExTC/ExTR19.0041/00

Quality Assessment Report:

GB/SIR/QAR07.0017/07



Certificate No.: IECEx ExTC 19.0008X Page 3 of 3

Date of issue: 2019-10-23 Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The RockMonitor XR System comprises a TX5002 RockMonitor XR Controller or a TX5003 RockMonitor XR Reader and up to 300 TX5001 RockMonitor XR Telltale units - the TX5002 or TX5003 powers and communicates with the TX5001 telltales in the system. The system measures displacement of the strata at anchor points in the roof or rib in an underground mine using the TX5001 Telltales. The TX5001 communicates the data back to the TX5002 controller or TX5003 Reader. The TX5002 controller is powered from a separately certified IS associated equipment and provides communication to surface monitoring equipment using Ethernet and/or RS485 signals and also contains two solid state relays that provide voltage free contacts. The TX5003 Reader is portable and powered by an integral battery pack. The TX5002 and TX5003 each provide user interface via keypad and LCD screen.

Refer to document P5625.129.IECEx for sytem details.

SPECIFIC CONDITIONS OF USE: YES as shown below:

Refer to Annexe for details

Annex:

Certificate Annex IECEx ExTC 19.0008X-0 Final.pdf



Annexe



Annexe for Certificate No.:

IECEx ExTC 19.0008X

Issue No.:


No.: 0

Specific Conditions of Use pertaining to Issue 0 of this Certificate:

The parameters listed below are for external connection to the TX5002 RockMonitor XR Controller for the connection of associated apparatus not specifically covered in the system block diagram (drawing P5625.129.IECEx) and must be considered in conjunction with the requirements shown in this table.

	Conn. P4 (Supply to TX5002)	Conn. P8 (Relay contacts – Relay A and Relay B)	Conn. P7 (RS485) - parameters for individual lines	Conn. J1 (Ethernet) – all lines combined
Terminal	1 wrt 2	4, 5, 6, 7, 8, 9	12, 13, 14, 15	
no.			wrt 11	
Ui	16 V or 14.4	30 V	8.4 V	17.64 V
	V (as			
	marked on			
	the			
	equipment)			
li	3.33 A	0.32 A		
Pi		530 mW		
Ci	4 μF	0 μF	0 μF	0.48 μF
Li	0 μΗ	0 μΗ	0 μH	30 μH
Uo		0 V	5.88 V	0 V dc
lo		0 A	66 mA	0 A dc
Po			97 mW	0 W dc
Со	_		1000 μF	1000 μF
Lo			26 mH	97 μH
Lo/Ro				145 μΗ/Ω

Refer below for example terminal number identification. The TX5002 Telltale connector shown in the example below may only be connected to the TX5001 RockMonitor XR Telltale units:



Conditions of use and user manuals applicable to each separately certified equipment comprising the system shall be observed.

Note that the Controlled System Limited 9474-ET Ethernet Interface (IECEx CML 16.0025X) listed as an option in the System Control Drawing (P5625.129.IECEx) is not certified by an Australian certification body and shall be taken into account as necessary.



Annexe



Annexe for Certificate No.: IECEx ExTC 19.0008X Issue No.: 0

Drawing list pertaining to Issue 0 of this Certificate:

Manufacturer's Documents	
--------------------------	--

Title:	Drawing No.:	Pages	Rev. Level:	Date:
RockMonitor XR System Control Drawing	P5625.129.IECEx	8	A	2019-10-11
(Various titles)				