



Scale

TOWN & COUNTRY PLASTICS, INC.
 POST OFFICE BOX 269
 MORGANVILLE, NJ 07751
 PHONE: (732) 780-5300 • FAX: (732) 294-0001

(21)
 (22)

METHOD 2A
 NEUTRALIZATION SYSTEM

DETAIL:
 METHOD 2A
 NEUTRALIZATION SYSTEM

Revisions	
ORIGINAL	12.14.2016
REV 1	6.13.2017
REV 2	9.22.2017



TOWN & COUNTRY PLASTICS
 Customized For Precision

DETAIL #5

- ① ACID VENT STACK
- ② MONITORING AND MIXING TANK #2
- ③ SAMPLING TANK #3
- ④ ACID FEED TANK #4 (ACID REAGENT TANK)
- ⑤ CAUSTIC / ALKALI FEED TANK #5 (CAUSTIC REAGENT TANK)
- ⑥ SPILL CONTAINMENT PALLET
- ⑦ CHEMICAL AGITATOR / MIXER
- ⑧ AGITATOR SHAFT AND MIXING BLADE
- ⑨ PH PROBE ASSEMBLY
- ⑩ PH PROBE SENSOR
- ⑪ CAUSTIC CHEMICAL FEED PUMP
- ⑫ ACID CHEMICAL FEED PUMP
- ⑬ PH PROBE ASSEMBLY WITH SUPPORT
- ⑭ ACID VENT CONNECTIONS
- ⑮ CONTROL PANEL
- ⑯ THREADED PP SCHEDULE 80 PIPE*
WITH THREADED JOINTS
WITH TEFLON TAPE
- ⑰ CONCRETE PAD OR EPOXY COATED STEEL STAND, BY INSTALLER
- ⑱ LOW LIQUID LEVEL ALARM ASSEMBLIES
- ⑲ POLYPROPYLENE LEAK DETECTOR WITH SWITCH BOX AND ALARMS
- ⑳ POLYPROPYLENE SHUT OFF VALVE
- ㉑ MODEL #WMS-1 SIGN
- ㉒ MODEL #WMS-2 SIGN
- ㉓ PP-44T LEAK DETECTION FLOAT ASSEMBLY TO BE INSTALLED IN SPILL CONTAINMENT PALLET AND/OR PIT FLOOR

T&C CAN PROVIDE AT EXTRA COST, IF LIST OF P-V-F GIVEN TO T&C BY PLUMBING CONTRACTOR, PRIOR TO INSTALLING

Seal

TOWN & COUNTRY PLASTICS, INC.
POST OFFICE BOX 269
MORGANVILLE, NJ 07751
PHONE: (732) 780-5300 - FAX: (732) 294-0001

METHOD 2A
NEUTRALIZATION SYSTEM DETAIL

DETAIL:
METHOD 2A
NEUTRALIZATION SYSTEM
DETAIL

Revisions:
ORIGINAL - 12.14.2016
REV 1 - 6.13.2017
REV 2 - 9.22.2017

Drawn: JIG
Checked: JIG
Scale: NTS
Date: 12.14.2016



TOWN & COUNTRY PLASTICS
Customized For Precision

DETAIL #6