



CERTIFICATION RECORD

The company named below has been authorized by CSA International to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

Alternate File: 268552

Class No: 2258 03 PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non Incendive Systems - For Hazardous Locations

LISTEE

4688305 Maratek Environmental Inc
60 Healey Rd, Unit 8
Bolton, ON L7E 5A5
Canada

November 2, 2016 (Replaces : NEW)

Class I, Division 1, Group D, Temperature Code T2A (280°C); Tamb=35°C max.

Solvent recycler units, permanently connected, stationary, with associated Intrinsically Safe Circuits, per manufacturers drawing 306050-EL.

Models:

SSB8a, rated 240Vac, 11.7A, 60Hz, 1-ph, 2.82kW

SSB16a, rated 240Vac, 23.4A, 60Hz, 1-ph, 5.32kW

SSB32a, rated 480Vac, 14.5A, or 600Vac, 11.3A, 60 Hz, 3-ph, 10.5kW

SSB48a, rated 480Vac, 20.8A, or 600Vac, 15A, 60 Hz, 3-ph, 15.5kW

Where, a = options (one or more of the following option codes are permitted):

blank, indicating no options

V, indicating vacuum option

F, indicating automatic filling option

L, indicating remote status indicating light option

S, indicating sludge temperature monitoring option

C, indicating stainless steel condenser option

Notes:

1. Associated Intrinsically Safe Circuits shall be connected per manufacturers drawing 306050-EL.
2. Installation, operation, and maintenance shall be in accordance with manufacturer's instruction manual for mounting clearances, appropriate deposit bag, specified solvents and conditions of use.
3. Final acceptance of installation is subject to inspection by the Authority Having Jurisdiction.

/ld



Certificate of Compliance

Certificate: 70102213

Master Contract: 268552

Project: 70102213

Date Issued: November 2, 2016

Issued to: Maratek Environmental
60 Healy Road
Bolton, ON L7E 5A5
CANADA
Attention: Colin Darcel

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and US Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: *Lizon Deschamps*
Lizon Deschamps

PRODUCTS

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non Incendive Systems - For Hazardous Locations

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non Incendive Systems - For Hazardous Locations – Certified to US Standards

Class I, Division 1, Group D, Temperature Code T2A (280°C); Tamb=35°C max.

Solvent recycler units, permanently connected, stationary, with associated Intrinsically Safe Circuits, per manufacturers drawing 306050-EL. Models:

- SSB8a, rated 240Vac, 11.7A, 60Hz, 1-ph, 2.82kW
- SSB16a, rated 240Vac, 23.4A, 60Hz, 1-ph, 5.32kW
- SSB32a, rated 480Vac, 14.5A, or 600Vac, 11.3A, 60 Hz, 3-ph, 10.5kW
- SSB48a, rated 480Vac, 20.8A, or 600Vac, 15A, 60 Hz, 3-ph, 15.5kW

Where, a = options (one or more of the following option codes are permitted):
blank, indicating no options



Certificate: 70102213

Master Contract: 268552

Project: 70102213

Date Issued: November 2, 2016

V, indicating vacuum option
F, indicating automatic filling option
L, indicating remote status indicating light option
S, indicating sludge temperature monitoring option
C, indicating stainless steel condenser option

Notes:

1. Associated Intrinsically Safe Circuits shall be connected per manufacturers drawing 306050-EL.
2. Installation, operation, and maintenance shall be in accordance with manufacturer's instruction manual for mounting clearances, appropriate deposit bag, specified solvents and conditions of use.
3. Final acceptance of installation is subject to inspection by the Authority Having Jurisdiction.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-10 - General Requirements - Canadian Electrical Code, Part II

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CSA-C22.2 No. 88-1958 - Industrial Heating Equipment

CSA-C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

ANSI/UL 508 (Seventeenth Edition) - Industrial Control Equipment

UL 823 (Ninth Edition) - Electric Heaters for Use in Hazardous (Classified) Locations

ANSI/UL 913 (Seventh Edition) - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations

ANSI/UL 1203 (Fourth Edition) - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

ANSI/UL 2208 (Third Edition) - Solvent Distillation Units

MARKINGS

Company's name, and/or CSA file number 268552, type designation, electrical ratings, serial number or date coding, the CSA Mark appear in a permanent manner on each unit, and any other information as specified in the Certification Report.

The cCSAus monogram may appear next to the CSA Mark.



Supplement to Certificate of Compliance

Certificate: 70102213

Master Contract: 268552

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description		
70102213	November 2, 2016	<u>Submittor Report</u>	<u>Submittor Model</u>	<u>Listee Models</u>
		1911732	SR30a SR60a SR120a SR180a	SSB8a SSB16a SSB32a SSB48a



CERTIFICATION RECORD

The company named below has been authorized by CSA International to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

Alternate
File: 268552

Class No: 2258 83 PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-Incendive Systems-For
Hazardous Locations-Certified to U.S. Standards

LISTEE

4688305 Maratek Environmental Inc
60 Healey Rd, Unit 8
Bolton, ON L7E 5A5
Canada

November 2, 2016 (Replaces : NEW)

Class I, Division 1, Group D, Temperature Code T2A (280°C); Tamb=35°C max.

Solvent recycler units, permanently connected, stationary, with associated Intrinsically Safe Circuits, per manufacturers drawing 306050-EL.

Models:

SSB8a, rated 240Vac, 11.7A, 60Hz, 1-ph, 2.82kW

SSB16a, rated 240Vac, 23.4A, 60Hz, 1-ph, 5.32kW

SSB32a, rated 480Vac, 14.5A, or 600Vac, 11.3A, 60 Hz, 3-ph, 10.5kW

SSB48a, rated 480Vac, 20.8A, or 600Vac, 15A, 60 Hz, 3-ph, 15.5kW

Where, a = options (one or more of the following option codes are permitted):

blank, indicating no options

V, indicating vacuum option

F, indicating automatic filling option

L, indicating remote status indicating light option

S, indicating sludge temperature monitoring option

C, indicating stainless steel condenser option

Notes:

1. Associated Intrinsically Safe Circuits shall be connected per manufacturers drawing 306050-EL.
2. Installation, operation, and maintenance shall be in accordance with manufacturer's instruction manual for mounting clearances, appropriate deposit bag, specified solvents and conditions of use.
3. Final acceptance of installation is subject to inspection by the Authority Having Jurisdiction.

/ld