



# 10,000LTR DIESEL STORAGE TANK WITH DISPENSING PUMP STATION

**INSTALLATION:**  
TANKS ARE TO BE INSTALLED ON A WELL COMPACTED, LEVELLED EARTH OR CONCRETE PAD, FREE FROM SHARP OR LOCALISED HARD STONES/OBJECTS THAT COULD DAMAGE THE TANK BASE. THE ROOF OF THIS TANK IS INTENDED ONLY TO COVER AND IS NOT TO BE TRAFFICABLE ROOF.

**MATERIAL:**  
LLDPE MATERIAL DESIGNED SPECIFICALLY FOR ROTATIONAL MOULDING APPLICATIONS DELIVERING A HIGH ESCR, CHEMICAL RESISTANCE, STIFFNESS AND TOUGHNESS WHICH IS UV STABILISED TO PROVIDE PROLONGED OUTDOOR PROTECTION IN HARSH AUSTRALIAN CONDITIONS. CERTIFIED BY TUV RHEINLAND KRAFTFAHRT GMBH FOR USE IN ROTATIONALLY MOULDED FUEL TANKS.

**STANDARDS:**  
ALL TANKS BY COERCO ARE MANUFACTURED TO CONFORM WITH AS1940:2017 WHEN USED WITH A BUND. STRUCTURALLY ENGINEERED TO CONFORM TO CYCLONIC AREAS AND STRESS ANALYSIS TESTING REQUIREMENTS.

**DIMENSIONS:**  
DIMENSIONS MAY VARY SLIGHTLY DUE TO THE SHRINKAGE NATURE OF POLYETHYLENE.

**NOTE:** THIS DRAWING DETAILS COERCO'S **STANDARD** DIESEL TANK FITOUT.



LOCKABLE PUMP CABINET WITH PUMP & AUTO SHUT-OFF NOZZLE (12, 24 & 240 VOLT OPTIONS)

ANTI-SPLASH AND ANTI-STATIC FILL LINE

LIQUID LEVEL INDICATOR

LOCKABLE PUMP CABINET WITH PUMP & AUTO SHUT-OFF NOZZLE (12, 24 & 240 VOLT OPTIONS)

STEEL LID WITH BREATHER

ANTI-SPLASH AND ANTI-STATIC FILL LINE

LIQUID LEVEL INDICATOR

50mm OUTLET WITH LOCKABLE BALL VALVE AND CAMLOCK

PERSPECTIVE VIEW

FLAT AREA FOR INLET/OVERFLOW

TANK SERIAL NUMBER

6 O'CLOCK VIEW

3 O'CLOCK VIEW

12 O'CLOCK VIEW

50mm OUTLET WITH LOCKABLE BALL VALVE AND CAMLOCK



DATE	15/03/2019
PRODUCT	10,000LTR DIESEL STORAGE TANK WITH DISPENSING PUMP STATION
PRODUCT CODE	DDS10000
DRAWING No	C-DDS10000-001

MATERIAL	LOW DENSITY POLYETHYLENE
SURFACE FINISH	POLISHED
WALL THICKNESS	
SCALE	NOT TO SCALE

REVISIONS					
REV	0	GT	15/03/2019	ORIGINAL CAD DRAWING ISSUED	
BY				DESCRIPTION	

SHEET 1 OF 1
CHKD
APVD
SHEET SIZE

© THIS DRAWING IS THE COPYRIGHT OF COERCO. IT CANNOT BE COPIED IN PART OR FULL WITHOUT THE WRITTEN PERMISSION OF COERCO