



Certificate No: (2017) W 01184



Suzhou Xinyi Inspection Technology Research Co., Ltd

Test certificate

Consignor Oliver-Tolas® Healthcare Packaging (Suzhou)Co., Ltd

Address Building 9, Suite B • No. 5 Chun Hui Road

Sample name Clean room

Sample specification	Gowning room	(ISO Class 8)
	Wash room	(ISO Class 8)
	Clean room	(ISO Class 8)
	Material shower room	(ISO Class 8)

Test standard

1.Cleanrooms and associated controlled environments Part 1:
Classification of air cleanliness by particle concentration
ISO14644-1: 2015


2.Cleanroom Particulate Monitoring-Suzhou WI-10V05

Conclusion Gowning room, Wash room, Clean room and Material shower room's cleanliness meet the requirements of ISO class 8 and WI-10V05 at the same time.

Authorized by  **Position** Chief Engineer

Test date 18 January 2017

Cal due to 17 January 2018



Address:No.188,Suhong East Road,
Founder Industrial Park Blk B#307, SIP
Http: www.xinyitesting.com

Tel: 0512-62931371
Post code: 215026

Fax: 0512-62931372
E-mail: xinyitesting@163.com