



## Offer Safety Notice: Square D General Duty Safety Switch 30/60A

### Safety Alert for General Duty 30 and 60A 120/240V, NEMA 3R Safety Switches

**Hazard:** The safety switch can potentially continue to supply electricity even in the "OFF" position. This poses a potential risk of an electric shock or electrocution hazard to consumers.

**Affected Products:** Impacted catalog numbers can be seen below. Products were manufactured from January 1, 2014 – January 18, 2018 (date codes 1401 – 1803 inclusive). The catalog number is located on a label on the outside of the safety switch. Information on locating the date code (for installed or uninstalled safety switch units) is included in the full inspection procedures.

**Remedy:** Schneider Electric has provided inspection procedures for products sold and currently installed. Products will be replaced for any non-conformity identified.



For more information call:

**877-672-1953**

Monday-Friday, 8-5 PM EST

Here is the link to the recall on Schneider's web page:

<https://www.schneider-electric.us/en/brands/squared/safety-notice/2018/general-duty-safety-switch/>

This safety alert is being conducted in cooperation with the US Consumer Product Safety Commission

# SafeALERT



ORCIG 2018 SafeAlert Series

This material is intended to be a broad overview of the subject matter and is provided for informational purposes only. Old Republic Contractors Insurance Group, Inc. does not endorse or recommend any products or services nor does it make any representation or warranty regarding the accuracy or completeness of the information. Old Republic Contractors Insurance Group, Inc. shall have no liability or responsibility to any person or entity with respect to any loss, action or inaction alleged to be caused directly or indirectly as a result of the information contained herein.

