D REPUBLIC CONTRACTORS INSURANCE GROUP

Leviton Manufacturing Recalls Electrical Connection Devices Due to Shock Hazard

Recall Date: April 23, 2020

Recall Number: 20-112

Description: This recall involves Leviton 50-ampere, non-NEMA electrical connectors, plugs, receptacles and inlet attachment devices. The recalled connection devices are used to transmit power to electrical equipment that is not hard-wired to a power source. Leviton is printed on the devices. Date codes can be found on the back cover of connectors and plugs, the side housing of receptacles and inlets, and on the label of each box. About 98,000 units were sold in the U.S.A; and about 4,400 units were sold in Canada. The recall includes the model/catalog numbers and date codes listed on the following page.

Hazard: The electrical connection devices can have mislabeled terminal markings, posing an electrical shock hazard.

Incidents/Injuries: Leviton has received four reports of mismarked devices, including one report of a consumer who received an electrical shock, and three reports of minor property damage to equipment with which the devices were being used.

Sold At: Electrical distributors and online at <u>www.Amazon.com</u> from May 2019 through January 2020 for be-tween \$40 and \$90.

Distributor(s): Leviton Manufacturing Co. Inc., of Melville, N.Y.

Manufactured In: Mexico

Remedy: Consumers should immediately stop using the recalled devices, disconnect power to them and contact Leviton to arrange for a free replacement device.

Contact Information: Call Leviton toll-free at 877-978-2032 from 8 a.m. to 6 p.m. ET Monday through Friday or online at <u>www.Leviton.com</u> and click on "Recall Information" for more information.

References and photos:

Consumer Product Safety Commission (CPSC)

https://www.cpsc.gov/Recalls/2020/Leviton-Manufacturing-Recalls-Electrical-Connection-Devices-Due-to-Shock-Hazard

Please contact your Safety Specialist for assistance with any questions you may have.



This material is intended to be a broad overview of the subject matter and is provided for informational purposes only. Old Republic Contractors Insurance Group, Inc. does not endorse or recommend any products or services nor does it make any representation or warranty regarding the accuracy or completeness of the information. Old Republic Contractors Insurance Group, Inc. shall have no liability or responsibility to any person or entity with respect to any loss, action or inaction alleged to be caused directly or indirectly as a result of the information contained herein.



The recall includes the following model/catalog numbers and date codes:

CATALOG NUMBERS		DATE CODES	
3762C	CS6365C	1E19C0	1I19C0
3763C	CS6365W	1E29C0	1I29C0
3764C	CS6369	1E39C0	1I39C0
3765C	CS6370	1E49C0	1I49C0
3769	CS6375	1E59C0	1159C0
3771	CS6377	1F19C0	1J19C0
3775	CS8264C	1F29C0	1J29C0
3777	CS8265C	1F39C0	1J39C0
6360CR	CS8269	1F49C0	1J49C0
6364CR	CS8275	1G19C0	1K19C0
6365CR	CS8464C	1G29C0	1K29C0
6369CR	CS8465C	1G39C0	1K39C0
6370CR	CS8469	1G49C0	1K49C0
6375CR	CS8164C	1H19C0	1K59C0
7379	CS8165C	1H29C0	1L19C0
7764C	CS8169	1H39C0	1L29C0
7765C	CS8175	1H49C0	
7958	CS8364C		
CS6360C	CS8365C		
CS6361C	CS8369		
CS6364C	CS837-410-5W1		
CS6364W	CS8375		

Only electrical connectors without a blue dot on the device and packaging are included in this recall.