COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

			DEL DATA						
1	Manufactu	rer:	Mattei C	ompressors					
2	Model Number: BLADE 22 i				Date:			May-18	
	X Air-cooled Water-cooled				Туре:			Vane	
	X Oil-injected Oil-free					# of Stages:	: 1		
3		d Operating Pressure				102	psig ^b		
4	Drive Motor Nominal Rating					30		hp	
5	Drive Motor Nominal Efficiency					93		percent	
6	Fan Motor Nominal Rating (if applicable)					n/a		hp	
7	Fan Motor Nominal Efficiency					n/a	percent		
8*	Input Power (kW)				Capacity (acfm) ^{a,d}		_	Specific Power (kW/100 acfm) ^d	
	25.85 Max					126.8		20.39	
	22.47					114.1		19.70	
	20.86					107.7		19.37	
	17.75					95.0		18.68	
	16.26					88.3	18.42		
	14.81 Mi:				81.9			18.08	
9*	Total Package Input Power at Zero Flow ^{c, d}					2.50	kW		
10		35.00							
		30.00							
	Specific Power (kW/100 ACFM)	25.00							
	Specifi (kW/100	20.00	0						
		15.00							
		10.00	25.0	50.0	75.0	100.0	125.0	150.0	
	Capacity (` '			
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity								


*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with

ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 031

Member

Compressed Air & Gas Institute

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data