COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR			
1 Manufacturer: Mattei Compressors Inc.			
2	Model Number: OPTIMA 132	Date:	Jan-17
	X Air-cooled Water-cooled	Type:	Vane
	X Oil-injected Oil-free	# of Stages:	1
3	Rated Operating Pressure	145	psig ^b
4	Drive Motor Nominal Rating	175	hp
5	Drive Motor Nominal Efficiency	96.2	percent
6	Fan Motor Nominal Rating (if applicable)	4.4	hp
7	Fan Motor Nominal Efficiency	n/a	percent
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	163.5 Max	728.2	22.45
	151.6	684.8	22.13
	128.3	597.2	21.49
	106.2	509.6	20.84
	95.5	465.8	20.49
	85.0 Min	421.7	20.16
9*	Total Package Input Power at Zero Flow ^{c, d}	14.5	kW
10	Note: Graph is only a visual r Note: Y-Axis Scale, 10 to 35, + 5kW	city (ACFM) epresentation of the data in Secti	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with


a. Measured a ne discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 031

Compressed Air & Gas Institute

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.