COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR		
1 Manufacturer: Mattei Compressors Inc.		
2	Model Number: OPTIMA 90	Date: Jan-17
	x Air-cooled Water-cooled	Type: Vane
	X Oil-injected Oil-free	# of Stages:
3	Rated Operating Pressure	145 psig ^b
4	Drive Motor Nominal Rating	120 hp
5	Drive Motor Nominal Efficiency	95.4 percent
6	Fan Motor Nominal Rating (if applicable)	3.2 hp
7	Fan Motor Nominal Efficiency	n/a percent
8*	Input Power (kW)	Capacity (acfm) ^{a,d} Specific Power (kW/100 acfm) ^d
	112.2 Ma	x 512.4 21.90
	104.1	483.5 21.54
	88.4	422.4 20.93
	73.3	358.8 20.43
	66.0	326.0 20.24
	58.8 Mi	n 292.8 20.08
9*	Total Package Input Power at Zero Flow ^{c, d}	9.9 kW
10	35.00	
	Specific Power (k.W/100 ACFM) 20'00 70'00 ACFM) 20'00 40'00 ACFM) 20'00 40'00	
	15.00	
	0 50 100 150 200	250 300 350 400 450 500 550
	Сар	acity (ACFM)
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org


a. Measured at the discharge terminal point of the compressor package in accordance with

ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 031

NOTES:

Member

Compressed Air & Gas Institute

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.