

Otto Aunola

17 March 2020

TGS-01901

Distribution

Antti Wickström

antti.wickstrom@efla.net

Reviewed by, Date

Mika Laiho, 17.3.2020

Approved by, Date

Osmo Koponen, 17.3.2020

Replace

IEC-61823 DECLARATION OF CONFORMITY

Ordered by Antti Wickström, EFLA Oy
Date and site 16.12.2019 – 13.3.2020, Otaniemi, Espoo
Carried out by Fortum Power and Heat Oy / TGS, Otto Aunola

STATEMENT

Total of nine AGL series transformers from three following nominal power classes KR631.1 of 45, KR636.1 of 65 and KR641.1 of 100 W were measured and tested according to chapter 6 of the IEC-61823 standard. All measurement instruments had valid calibrations according to Fortum calibration procedure.

All test details and results are presented in TGS-01901 standard test report. According to results it can be confirmed that the transformers meet the requirements set by the IEC-61823 standard.