

ICC-ES Report

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

Most Widely Accepted and Trusted

PMG-1264

Reissued 09/21//2018 This report is subject to renewal 06/2019

EVALUATION SUBJECT:

SURFACE BURNING CHARACTERISTICS FOR FLOWGUARD GOLD[®], PRODUCTS MADE WITH TEMPRITE[®] TECHNOLOGY, AND CORZAN[®] CPVC PIPE AND FITTINGS

DIVISION: 23 00 00—MECHANICAL SECTION: 23 00 00—HVAC

Report Holder:

LUBRIZOL ADVANCED MATERIALS, INC.

Look for the ICC-ES marks of Conformity!



ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report. Copyright © 2018 ICC Evaluation Service, LLC. All rights reserved.













ICC-ES PMG Product Certificate

PMG-1264

ISO/IEC 17065 Product Certification Body s100 Effective Date: June 2018 Revision Date: September 21, 2018 This listing is subject to re-examination in one year.

www.icc-es-pmg.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 23 00 00—MECHANICAL Section: 23 00 00—HVAC

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

- **Product:** Surface Burning Characteristics for FlowGuard Gold[®], Products made with TempRite[®] Technology, and Corzan[®] CPVC Pipe and Fittings
- Listee: Lubrizol Advanced Materials, Inc. 9911 Brecksville Road Cleveland, Ohio 44141 www.lubrizol.com/cpvc

Additional Companies:

Bow Industrial Corporation (FlowGuard Gold[®] Pipe and Fittings) 15 Vittie Street Granby, QC J2G 6N8 Canada www.bow-group.com

Charlotte Pipe and Foundry Company (FlowGuard Gold® Pipe and Fittings) 2109 Randolph Road Charlotte, NC 28207 www.charlottepipe.com

Cresline Plastic Pipe Co., Inc. (FlowGuard Gold[®] Pipe) 600 Cross Pointe Boulevard Evansville, IN 47715 <u>www.cresline.com</u>

Genova Products, Inc. (FlowGuard Gold[®] Pipe and Fittings) P.O. Box 309 Davison, MI 48423 <u>www.genovaproducts.com</u>

Georg Fischer Harvel LLC (FlowGuard Gold[®] Pipe and Corzan[®] ChlorFIT[®] Pipe and Fittings) 300 Kuebler Road Easton, PA 18040 <u>www.harvel.com</u>

Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.

IPEX USA LLC (Corzan[®] Pipe and Fittings and AquaRise[®] made with TempRite[®] Technology Pipe and Fittings) 2441 Royal Windsor Drive Mississauga, On L5J 4C7 Canada www.ipexamerica.com

NIBCO Inc.(FlowGuard Gold[®] fittings and Corzan[®] fittings) 1516 Middlebury Street Elkhart, Indiana 46516 <u>www.nibco.com</u>

Compliance with the following codes:

2018, 2015, 2012, 2009 and 2006 International Mechanical Code[®] (IMC) 2018, 2015, 2012, 2009 and 2006 Uniform Mechanical Code[®] (UMC)*

*Copyrighted publication of the International Association of Plumbing and Mechanical Officials

Compliance with the following standards:

ASTM E 84-18, Test Method for Surface Burning Characteristics of Building Materials UL 723 (Ed. 11), Test for Surface Burning Characteristics of Building Materials

Identification:

Pipe must bear the manufacturer's name or trademark, test standard, rating and the ICC-ES PMG listing mark.

Fittings must bear manufacturer's name or trademark, nominal size and a third party certification mark. Packaging must be marked with test standard, rating and ICC-ES PMG listing mark.

Installation:

The pipe and fittings are to be installed in accordance with the manufacturer's instructions and the applicable code.

Installation of pipe and fittings within ducts and plenums shall be in accordance with Section 602 of the IMC or 602.0 of the UMC

Models:

The following CPVC pipe and fittings models have been tested as a single row of four 24 in. pipe lengths placed end to end, with a coupling between each length followed by a 15 ft. length of pipe either water-filled or dry as a modified* version of UL 723 / ASTM E 84, Test Methods for Surface Burning Characteristics. The following ratings were obtained and have been found to meet the 25/50 flame spread/smoke developed requirements.

- 1/2" 2" water-filled FlowGuard Gold[®] CPVC pipe and fittings have a flame spread index of no more than 5 and a smoke developed index of no more than 35.
- 1/2" 2" dry FlowGuard Gold[®] CPVC pipe and fittings for condensate lines have a flame spread index of no more than 5 and a smoke developed index of no more than 25.
- 1/2" 6" water-filled Corzan[®] CPVC pipe and fittings have a flame spread index of 0 and a smoke developed index of no more than 20.
- 1/2" 2" dry Corzan[®] CPVC pipe and fittings for condensate lines have a flame spread index of no more than 0 and a smoke developed index of no more than 20.
- 1/2" 4" water-filled Products made with TempRite® Technology CPVC pipe and fittings have a flame spread index of 0 and a smoke developed index of no more than 20.
- * The specimens tested are not conducive to full coverage of the 20 in. x 24 ft. test sample as specified by UL 723/ASTM E84. Therefore, only a certain portion of the total area exposed to the flame is covered by the test samples. The tested specimens are representative models of finish product.

Conditions of listing:

- 1. The pipe and fitting models recognized by this listing have been evaluated for surface burning characteristics only. Evaluation of the CPVC pipe and fittings to the applicable performance standard in accordance with Chapter 6 of the IPC or UPC is outside the scope of this report.
- 2. The plumbing systems must be installed in accordance with the applicable codes.
- 3. The CPVC resin used in the manufacturing of the pipe and fittings covered by this report were supplied by Lubrizol and are under a quality control program with annual surveillance inspections by ICC-ES.