

ANTIFREEZE SOLUTION REQUIREMENTS PER NFPA STANDARDS

STANDARD	SECTION	PROPYLENE GLYCOL	GLYCERIN
NFPA 13	*13:19, 8.6.2	Shall be listed for use in sprinkler systems	Shall be listed for use in sprinkler systems
NFPA 13D	13D:19, 9.2.2	Shall be listed for use in sprinkler systems or 38% with AHJ approval	Shall be listed for use in sprinkler systems or 48% with AHJ approval
NFPA 13R	*13R:19, 5.4.2	Follow NFPA 13: Shall be listed for use in sprinkler systems	Follow NFPA 13: Shall be listed for use in sprinkler systems
NFPA 25 All systems installed prior to 9/30/2012	25:17, 5.3.3.4	 Before 9/30/2022 Listed antifreeze or: Pre-mixed non-listed 30% by volume Pre-mixed non-listed between 30-40% with a deterministic risk assessment and AHJ approval After 9/30/2022 Listed antifreeze 	 Before 9/30/2022 Listed antifreeze or: Pre-mixed non-listed 38% by volume Pre-mixed non-listed between 38-50% with a deterministic risk assessment and AHJ approval After 9/30/2022 Listed antifreeze
NFPA 25 All systems installed after 9/30/2012	25:17, 5.3.3.4.1	Shall be listed for use in sprinkler systems	Shall be listed for use in sprinkler systems

Note: New listed solutions are not required to be glycerin or glycol based as long as they pass UL 2901

*Effective since 2013 version

The information contained herein is reliable based on current information but the advertiser makes no representations, guarantees or warranties, express or implied, including any implied warranties of merchantability or fitness for a particular purpose, or regarding the completeness, accuracy, or timeliness of any information. Always consult your pipe and/or fitting manufacturer for current recommendations.

©Lubrizol Advanced Materials, Inc. 2020, all rights reserved.

All marks are property of Lubrizol Advanced Materials, a Berkshire Hathaway Company. 20-0240200

