# DIESEL GENERATOR SET MTU 20V4000 DS2500

2500 kWe / 60 Hz / Standby 380 - 13.8kV

Reference MTU 20V4000 DS2500 (2250 kWe) for Prime Rating Technical Data



# SYSTEM RATINGS

#### Standby

Voltage (L-L)	380V	480V*	600V	4160V	12470V	13200V	13800V
Phase	3	3	3	3	3	3	3
PF	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Hz	60	60	60	60	60	60	60
kW	2500	2500	2500	2500	2500	2500	2500
kVA	3125	3125	3125	3125	3125	3125	3125
Amps	4748	3759	3007	434	145	137	131
skVA@30%							
Voltage Dip	3400	4625	5200	5800	4300	4750	5350
Generator							
Model	1020FDL1104	1020FDL1102	1020FDS1122	1020FDM 1180	1020FDH1248	1020FDH1248	1030FDH 1250
Temp Rise	130 °C/40 °C						
Connection	6 LEAD WYE						

\* UL 2200 Offered

# CERTIFICATIONS AND STANDARDS

- // Emissions EPA Tier 2 Certified
- // Generator set is designed and manufactured in facilities certified to standards ISO 9001:2008 and ISO 14001:2004

#### // Seismic Certification – Optional

- IBC Certification
- OSHPD Pre-Approval
- // UL 2200 Listed Optional

#### // Performance Assurance Certification (PAC)

- Generator Set Tested to ISO 8528-5 for Transient Response
- Verified product design, quality and performance integrity
- All engine systems are prototype and factory tested

#### // Power Rating

- Accepts Rated Load in One Step Per NFPA 110
- Permissible average power output during 24 hours of operation is approved up to 85%.

## STANDARD FEATURES\*

- // MTU Onsite Energy is a single source supplier
- // Global Product Support
- // 2 Year Standard Warranty
- // 20V4000 Diesel Engine
  - 95.4 Liter Displacement
  - Common Rail Fuel Injection
  - 4-Cycle
- // Complete Range of Accessories

#### // Generator

- Brushless, Rotating Field Generator
- 2/3 Pitch Windings
- PMG (Permanent Magnet Generator) supply to regulator
- 300% Short Circuit Capability
- // Digital Control Panel(s)
  - UL Recognized, CSA Certified, NFPA 110
  - Complete System Metering
  - LCD Display
- // Cooling System
  - Integral Set-Mounted
  - Engine-Driven Fan

## STANDARD EQUIPMENT\*

#### // Engine

Air Cleaners	No Load to Full Load Regulation	
Oil Pump	Brushless Alternator with Brushless Pilot Exciter	
Oil Drain Extension and S/O Valve	4 Pole, Rotating Field	
Full Flow Oil Filters	130 °C Max. Standby Temperature Rise	
Closed Crankcase Ventilation	2 Bearings, Sealed	
Jacket Water Pump	Flexible Coupling	
Inter Cooler Water Pump	Full Amortisseur Windings	
Thermostats	125% Rotor Balancing	
Blower Fan and Fan Drive	3-Phase Voltage Sensing	
Radiator - Unit Mounted	±0.25% Voltage Regulation	
Electric Starting Motor - 24V	100% of Rated Load - One Step	
Governor – Electronic Isochronous	5% Max. Total Harmonic Distortion	
Base - Structural Steel		
SAE Flywheel and Bell Housing		
Charging Alternator - 24V	<pre>// Digital Control Panel(s)</pre>	
Battery Box and Cables		

Flexible Fuel Connectors Flexible Exhaust Connection EPA Certified Engine

NEMA MG1, IEEE and ANSI standards compliance for temperature rise	Re
and motor starting	Pro
Sustained short circuit current of up to 300% of the rated current for	UL
up to 10 seconds	Ev
Self-Ventilated and Drip-Proof	IP
Superior Voltage Waveform	NF
Digital, Solid State, Volts-per-Hertz Regulator	

Digital Meter	ing
Engine Paran	neters
Generator Pr	otection Functions
Engine Prote	otion
CANBus ECU	Communications
Windows <sup>®</sup> -Ba	sed Software
Multilingual (	Capability
Remote Com	munications to RDP-110 Remote Annunciator
Programmab	e Input and Output Contacts
UL Recognize	d, CSA Certified, CE Approved
Event Record	ing
IP 54 Front P	anel Rating with Integrated Gasket
NFPA110 Cor	npatible

\* Represents standard product only. Consult Factory/MTU Onsite Energy Distributor for additional configurations.

# APPLICATION DATA

## // Engine

Manufacturer	MTU
Model	20V4000G43 6 ECT
Туре	4-Cycle
Arrangement	20-V
Displacement: L (in <sup>3</sup> )	95.4 (5,822)
Bore: cm (in)	17 (6.69)
Stroke: cm (in)	21 (8.27)
Compression Ratio	16.4:1
Rated RPM	1,800
Engine Governor	Electronic Isochronous (ADEC)
Max. Power: kWm (bhp)	2,740 (3,674)
Speed Regulation	±0.25%
Air Cleaner	Dry

## // Liquid Capacity (Lubrication)

Total Oil System: L (gal)	390 (103)
Engine Jacket Water Capacity: L (gal)	205 (54.2)
After Cooler Water Capacity: L (gal)	30 (7.9)
System Coolant Capacity: L (gal)	814 (215)

## // Electrical

Electric Volts DC	24
Cold Cranking Amps Under - 17.8 °C (0 °F)	4,200

## // Fuel System

Fuel Supply Connection Size	-16 JIC 37° Female
	1" NPT Adapter Provided
Fuel Return Connection Size	-16 JIC 37° Female
	1" NPT Adapter Provided
Max. Fuel Lift: m (ft)	1 (3)
Recommended Fuel	Diesel #2
Total Fuel Flow: L/hr (gal/hr)	1,620 (428)

## // Fuel Consumption

At 100% of Power Rating: L/hr (gal/hr)	636 (168)
At 75% of Power Rating: L/hr (gal/hr)	507 (134)
At 50% of Power Rating: L/hr (gal/hr)	363 (96)

## // Cooling - Radiator System

Ambient Capacity of Radiator: °C (°F)	54 (129)
Max. Restriction of Cooling Air: Intake	
and Discharge Side of Rad.: kPa (in. H <sub>2</sub> 0)	0.12 (0.5)
Water Pump Capacity: L/min (gpm)	1,567 (414)
After Cooler Pump Capacity: L/min (gpm)	567 (150)
Heat Rejection to Coolant: kW (BTUM)	940 (53,456)
Heat Rejection to After Cooler: kW (BTUM)	630 (35,827)
Heat Radiated to Ambient: kW (BTUM)	209 (11,895)
Fan Power: kW (hp)	87.5 (117.3)

## // Air Requirements


Aspirating: *m <sup>3</sup> /min (SCFM)	225 (7,946)
Air Flow Required for Rad.	
Cooled Unit: *m <sup>3</sup> /min (SCFM)	2,895 (102,247)
Remote Cooled Applications;	
Air Flow Required for Dissipation	
of Radiated Generator Set Heat for a	
Max. of 25 °F Rise: *m <sup>3</sup> /min (SCFM)	784 (27,686)

\* Air density = 1.184 kg/m<sup>3</sup> (0.0739 lbm/ft<sup>3</sup>)

## // Exhaust System

Gas Temp. (Stack): °C (°F)	455 (851)
Gas Volume at Stack	
Temp: m³/min (CFM)	540 (19,070)
Max. Allowable	
Back Pressure: kPa (in. H <sub>2</sub> 0)	8.5 (34.1)

## WEIGHTS AND DIMENSIONS



Drawing above for illustration purposes only, based on standard open power 480 volt generator set. Lengths may vary with other voltages. Do not use for installation design. See website for unit specific template drawings.



Weights and dimensions are based on open power units and are estimates only. Consult the factory for accurate weights and dimensions for your specific generator set.

# SOUND DATA

Unit Type Level 0: Open Power Unit dB(A)

Standby Full Load 97.5

Sound data is provided at 7 m (23 ft). Generator set tested in accordance with ISO 8528-10 and with infinite exhaust.

# **EMISSIONS DATA**



All units are in g/hp-hr and shown at 100% load (not comparable to EPA weighted cycle values).

Emission levels of the engine may vary with ambient temperature, barometric pressure, humidity, fuel type and quality, installation parameters, measuring instrumentation, etc. The data was obtained in compliance with US EPA regulations. The weighted cycle value (not shown) from each engine is guaranteed to be within the US EPA Standards.

# RATING DEFINITIONS AND CONDITIONS

// Standby ratings apply to installations served by a reliable utility source. The standby rating is applicable to varying loads for the duration of a power outage. No overload capability for this rating. Ratings are in accordance with ISO 8528-1, ISO 3046-1, BS 5514, and AS 2789. Average load factor: ≤ 85%.

// Deration Factor:

Altitude: Consult your local MTU Onsite Energy Power Generation Distributor for altitude derations. Temperature: Consult your local MTU Onsite Energy Power Generation Distributor for temperature derations.

MTU Onsite Energy A Rolls-Royce Power Systems Brand 0

MTU Onsite Energy. Subject to alteration due to technological advances. OE 23 699 (77 3E) 2017-06