

Model 202HD – Insulated Commercial Sheet Door

Part 1 - GENERAL

1.01 DESCRIPTION

- A. Type:** Insulated Commercial Sheet Doors to be manufactured by Asta Door Corporation.
- B. Operation:** to be hand chain operated using reduction drive.
- C. Mounting:** to be interior face mounted on a prepared opening.

1.02 RELATED WORK

- A.** Opening preparation, access panels, finish or field painting are in the scope of the work of other sections or trades.

Part 2 - PRODUCT

2.01 CURTAIN

- A. Sheet:** 26 gauge galvanized grade 80 full hard steel roll formed in continuous corrugation. Galvanized according to A.S.T.M. A653-G60 and finished with baked epoxy primer and baked polyester topcoat.
- B. Side Stripping:** p.v.c. rubber to be attached to curtain edges.
- C. Bottom Bar:** curtain to be reinforced with a bottom bar consisting of 2" x 1-1/2" x 12 gauge galvanized steel angle with E.P.D.M. astragal.
- D. Insulation:** to be mylar and polyethylene insulation laminated to corrugated sheet.

2.02 DRUM ASSEMBLY

- A. Drum:** to be formed with 26 gauge galvanized steel sheet rolled around and attached to stamped 16 gauge galvanized steel drums to restrict deflection to .03" per foot (2.5 mm/m) of door width.
- B. Springs:** to be oil tempered, grease packed helical torsion type designed to cycle 12,500 times with an overload factor of 25%. Springs are to be mounted on a 1-5/16" (25.4mm) hot rolled steel tubing of minimum 14 gauge for up to 10' wide doors, otherwise 11 gauge minimum.

2.03 SUPPORT BRACKETS

- A. Support Brackets:** to be 3/16" (4.76mm) thick structural steel angles and a 1/4" (6.35mm) thick steel diagonal brace welded in a triangular form to support ends of drum assembly.

2.04 OPERATION

- A. Chain Hoist:** to be cast iron pocket wheel drive with machine link hand chain.

2.05 GUIDE ASSEMBLY

- A. Guides:** to be roll formed 12 gauge galvanized steel channels.
- B. Guide Depth:** 3-1/2" deep per side to provide sheet penetration adequate for proper operation.

2.06 WEATHER SEAL

- A. Side Draft Seal:** Brush Seal with aluminum retainer (field installed).
- B. Top Draft Stop:** to be E.P.D.M. seal attached to top of curtain to seal against header (field installed).

2.07 LOCKING

- A. Hand Chain Lock:** bracket, to be mounted on guide angle or wall for chain operated doors.
- B. Curtain Lock:** to be hardened galvanized steel slide bolts attached to bottom angle suitable for padlocking. (padlock by others)

2.08 FINISH

- A. Ungalvanized Surfaces:** to be shop coated with rust reducing black prime paint.

2.09 EFFICIENCY

- A. Rating:** overall efficiency rating of R=5.24 (U=0.191).

Part 3 - EXECUTION

3.01 INSTALLATION

- A. Installation:** to be by Asta Door Corporation, authorized representative according to Asta Door Corporation standards and instructions.