



**G5543.01-113-11-R0  
ACOUSTICAL PERFORMANCE TEST REPORT  
ASTM E90**

**Rendered to:**

**ODL INCORPORATED**

**SERIES/MODEL: Evolve**

**TYPE: Door Lite Kit with Insulating Glass Unit**

<b>Summary of Test Results</b>			
<b>Data File No.</b>	<b>Glazing (Nominal Dimensions)</b>	<b>STC</b>	<b>OITC</b>
G5543.01A1	1" IG (5/16" laminated exterior, 9/16" air space, 1/8" tempered interior), Glass temperature 75°F	34	28
G5543.01B	Decorative 1" IG (5/16" laminated exterior, 7/32" air space, 1/8" deco-annealed center, 7/32" air space, 1/8" tempered interior), Glass temperature 75°F	37	30

Reference should be made to Intertek-ATI Report No. G5543.01-113-11 for complete test specimen description. This page alone is not a complete report. Flanking limit tests and reference specimen tests are available upon request.